



- NOTE : -
1. ALL PIPE DIAMETERS GIVEN ARE NOMINAL OUT SIDE DIAMETERS.
  2. MAN HOLE HEIGHT DEPENDS ON SITE CONDITION & LEVEL OF THE PIPE.
  3. COVER TO R/F TO BE 40mm.
  4. ALL MANHOLE COVER SLAB R/F GRADE CONCRETE TO BE C.30 AND OTHER ALL STRUCTURAL R/F CONCRETE GRADE TO BE C.35

FOOTING DETAIL	
TYPE	SIZE(mm)
F1	1500 x 1500 x 300 th.

COLUMN DETAIL	
TYPE	SIZE(mm)
C1	300 x 300

CONCRETE GRADE 35 A  
FLY ASH BLENDED CEMENT

Rev.	Date	Desd.	Description	Dwn.	Chkd	App'd
Client DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA MINISTRY OF HIGHER EDUCATION						
Project <b>PROPOSED ALTERNATIVE WATER SUPPLY SYSTEM FOR UVA WELLSA UNIVERSITY</b>						
Title <b>WATER SUMP R/F DETAIL</b> ( SHEET 02 OF 02 )						
<b>CENTRAL ENGINEERING CONSULTANCY BUREAU</b> DESIGN OFFICE - CONSULTANCY SERVICES SECTION, DIGANA						
Head Office : 415, Baudhaloka Mawatha, Colombo-07, Sri Lanka.			Base Office : Digana Village, Rajawella, Sri Lanka.			
Tel. - 011 2668800			Tel. - 081 2376324, 081 2375286, 081 2375480			
Fax - 011 2667369			Fax - 081 2375480			
E-Mail - cecb@sl.lk			E-Mail - cecbdigana@gmail.com			
Designed	AMARAJEEWA (S-DE)	Recommended -		DGM (CP)		
Drawn	KASUN	Approved -		AGM (CP)		
Checked	R.K.C.T.	Scale	Date	Status		
Submitted	LJITHRA	As Shown	DEC. 2020	<b>TEN.</b>		
Plot Code	142042122914 00 15 42 29 476.67	Sheet Size		Drawing No.		
A3	C 662.WS/ CSD / PL - 04		Rev. No.			

**BASEMENT SLAB R/F DETAIL**  
SCALE 1 : 50

This drawing is sole property of CECB. Data contained on this drawing shall not be used, reproduced, duplicated in whole or part without the prior permission of CECB. CECB shall not be hold responsible for the unauthorized use of this drawing on Projects other than for which it was used.